



ਦਫਤਰ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ, ਕਪੂਰਥਲਾ
ਵਾਟਰ ਵਰਕਸ ਪਿੰਡ ਪਾਲੀਵਾਲ ਦੋਨਾਂ, ਕਪੂਰਥਲਾ
ਈ-ਮੇਲ xen.kapurthala@gmail.com

ਵਿਖੇ

Principal,
British Sikh School,
Near Science City,
Ibban Road Khojewal,
District Kapurthala

ਨੰ.3256

ਮਿਤੀ 30-07-24

ਵਿਸ਼ਾ :- Certificate for Good Water and Sanitary Conditions.

ਹਵਾਲਾ :- ਆਪ ਦੇ ਦਫਤਰ ਦਾ ਪੱਤਰ ਨੰ. BSS/2024/160 ਮਿਤੀ 05.07.2024

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਨੂੰ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ.1, ਕਪੂਰਥਲਾ ਵੱਲੋਂ ਆਪਣੇ ਦਫਤਰ ਦੇ ਪੱਤਰ ਨੰ. 325 ਮਿਤੀ 30.07.2024 ਰਾਹੀਂ ਇਸ ਦਫਤਰ ਨੂੰ ਰਿਪੋਰਟ ਦਿੱਤੀ ਹੈ ਕਿ ਆਪ ਦੇ ਸਕੂਲ ਵਿਖੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦੀ ਪ੍ਰੋਵੀਜ਼ਨ ਤਸੱਲੀਬਖਸ਼ ਪਾਈ ਗਈ ਹੈ। ਇਸ ਲਈ ਆਪ ਨੂੰ ਸਾਲ 2024-25 ਤੱਕ ਲਈ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦਾ ਸਰਟੀਫਿਕੇਟ ਇਸ ਸ਼ਰਤ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇਕਰ ਇਸ ਸਮੇਂ ਦੌਰਾਨ ਮੁੜ ਚੈਕਿੰਗ ਕਰਨ ਤੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਵਿੱਚ ਕੋਈ ਕਮੀ ਪੇਸ਼ੀ ਪਾਈ ਜਾਂਦੀ ਹੈ ਤਾਂ ਇਹ ਸਰਟੀਫਿਕੇਟ ਰੱਦ ਕਰਨ ਦਾ ਹੱਕ ਵਿਭਾਗ ਪਾਸ ਰਾਖਵਾਂ ਹੋਵੇਗਾ।

ਇਹ ਆਪ ਦੀ ਸੂਚਨਾ ਹਿੱਤ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ
ਕਪੂਰਥਲਾ

ਪਿੱਠ ਅੰਕਣ ਨੰ.

ਮਿਤੀ

ਉਪਰੋਕਤ ਦੀ ਨਕਲ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ.1, ਕਪੂਰਥਲਾ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ. 325 ਮਿਤੀ 30.07.2024 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜੀ ਜਾਂਦੀ ਹੈ।

Principal
BRITISH SIKH SCHOOL
Near Science City Khojewal (Kpt.)

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ
ਕਪੂਰਥਲਾ।

ਭੁਲੀ ਵਿਰਾਸਤ ਨੂੰ ਫਿਰ ਪਾਈਏ, ਜਿਲ੍ਹਾ ਕਪੂਰਥਲਾ ਨੂੰ ਸਵੱਛ ਬਣਾਈਏ

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dona, water works, Kapurthala
dwtlkpt@gmail.com

To,

S.D.E SUB DIV NO 1 KPT
KAPURTHALA

No.: DWTLKPT/2425/00068 Dated : 24/07/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 283 Dated: 18/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 18/07/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Kapurthala

D/A: Test Report



Authorized Signatory
For, District water Testing Laboratory
Kapurthala



Principal
BRITISH SIKH SCHOOL
Near Science City, Khojewal (Kpt.)

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dora, water works, Kapurthala
dwtlkpt@gmail.com

TEST REPORT						
Name & Address of Customer : S.D.E SUB DIV NO 1 KPT KAPURTHALA			Customer Reference No.		No : 283 Dated : 18/07/2024	
			Sample Submitted by		ASHISH RANA J.E	
			Date of Sample Receipt		18/07/2024	
			Analysis Starting Date		22/07/2024	
			Analysis completion Date		23/07/2024	
Discipline : Chemical Testing, Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		DWTLKPT/2425/00068		Date of Issue :		24/07/2024
Registration no.:		DWTLKPT/REG2425/00259		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		500 ml / Amber Coloured Sample Bottle - 500 mL
Scheme/Source:		Not Mentioned (Not Mentioned)		Location/Depth :		BRITISH SIKH SCHOOL (KHOJEVAL) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Kapurthala		District :		Kapurthala
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.81	6.5-8.5	No Relaxation	-	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	-	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	-	IS 3025 (Part 8 - 2023)
5	TDS	250	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.60	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity (CaCO ₃)	179.10	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness (CaCO ₃)	168	200	600	mg/l	IS 3025 (Part 21- 2009) (RA 2019) EDTA Method
9	Calcium (Ca)	32.06	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium (Mg)	21.38	30	100	mg/l	APHA (24th Ed. 2023) Method: 3500-Mg-2 B By Calculation Method
11	Chloride (Cl)	19.85	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
12	Bacteriological Contamination (B)	ABSENT			-	H2S Vial

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Kapurthala

End of the Test Report

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dona, water works, Kapurthala
dwtlkpt@gmail.com

TEST REPORT

Name & Address of Customer : S.D.E SUB DIV NO 1 KPT KAPURTHALA			Customer Reference No.		No : 283 Dated : 18/07/2024	
			Sample Submitted by		ASHISH RANA J.E	
			Date of Sample Receipt		18/07/2024	
			Analysis Starting Date		22/07/2024	
			Analysis completion Date		23/07/2024	
Discipline : Chemical Testing, Bacteriological Testing						
ULR No.:			Sample Type :		Water	
Test Report No.:			Date of Issue :		24/07/2024	
Registration no.:			Condition of Sample :		Unsealed	
Collection Point:			Quantity/Type of Bottle:		500 ml / Transparent Glass Bottle	
Scheme/Source:			Location/Depth :		BRITISH SIKH SCHOOL (KHOJEWAL) / NA	
Village :			Habitation :		Not Mentioned	
Block:			District :		Kapurthala	
Latitude :			Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.47	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	240	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.50	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	175.12	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	160	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	36.87	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	16.52	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	21.83	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
12	Bacteriological Contamination(B)	ABSENT			--	H2S Vial

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Kapurthala

End of the Test Report