



ਦਫਤਰ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ, ਕਪੂਰਥਲਾ
ਵਾਟਰ ਵਰਕਸ ਪਿੰਡ ਧਾਲੀਵਾਲ ਦੋਨਾਂ, ਕਪੂਰਥਲਾ
ਈ-ਮੇਲ eedwssdivkapurthala@yahoo.com

ਵਿਖੇ

British Sikh School,
Ibban Road,
Near Science City
Khojewal,
District Kapurthala.

ਨੰ. 4366


ਮਿਤੀ 02-07-25

ਵਿਸ਼ਾ :- Certificate for Good Water and Sanitary Conditions.

ਹਵਾਲਾ:- ਆਪ ਦਾ ਪੱਤਰ ਨੰ. BSS/2025/292 ਮਿਤੀ 21.05.2025

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਨੂੰ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ.1, ਕਪੂਰਥਲਾ ਵੱਲੋਂ ਆਪਣੇ ਪੱਤਰ ਨੰ. 483 ਮਿਤੀ 02.07.2025 ਰਾਹੀਂ ਇਸ ਦਫਤਰ ਨੂੰ ਰਿਪੋਰਟ ਦਿੱਤੀ ਹੈ ਕਿ ਆਪ ਦੇ ਸਕੂਲ ਵਿਖੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦੀ ਪ੍ਰੋਵੀਜ਼ਨ ਤਸੱਲੀਬਖਸ਼ ਪਾਈ ਗਈ ਹੈ। ਇਸ ਲਈ ਆਪ ਨੂੰ ਸਾਲ 2025-26 ਤੱਕ ਲਈ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਦਾ ਸਰਟੀਫਿਕੇਟ ਇਸ ਸ਼ਰਤ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਜੇਕਰ ਇਸ ਸਮੇਂ ਦੌਰਾਨ ਮੁੜ ਚੈਕਿੰਗ ਕਰਨ ਤੇ ਜਨ ਸਿਹਤ ਸੇਵਾਵਾਂ ਵਿੱਚ ਕੋਈ ਕਮੀ ਪੇਸ਼ੀ ਪਾਈ ਜਾਂਦੀ ਹੈ ਤਾਂ ਇਹ ਸਰਟੀਫਿਕੇਟ ਹੱਦ ਕਰਨ ਦਾ ਹੱਕ ਇਸ ਵਿਭਾਗ ਪਾਸ ਰਾਖਵਾਂ ਹੋਵੇਗਾ।

ਇਹ ਆਪ ਸੂਚਨਾ ਹਿੱਤ ਹੈ।



ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ
ਕਪੂਰਥਲਾ

ਪਿੱਠ ਅੰਕਣ ਨੰ.

ਮਿਤੀ

ਉਪਰੋਕਤ ਦੀ ਨਕਲ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ.1, ਕਪੂਰਥਲਾ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ. 483 ਮਿਤੀ 02.07.2025 ਸੂਚਨਾ ਹਿੱਤ ਭੇਜੀ ਜਾਂਦੀ ਹੈ।


Principal
BRITISH SIKH SCHOOL
Near Science City, Khojewal (Kpt.)


ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਮੰਡਲ
ਕਪੂਰਥਲਾ।

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gnul.com

TEST REPORT

Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No.1 Kapurthala SDE Water Supply and Sanitation Sub Division No.1 Kapurthala		Customer Reference No. No : 464 Dated : 25/06/2025
		Sample Submitted by Mr. Lakhbir Singh
		Date of Sample Receipt 25/06/2025
		Analysis Starting Date 25/06/2025
		Analysis completion Date 28/06/2025
Discipline : Bacteriological Testing		Group: Water
ULR No.:		Sample Type : Water
Test Report No.:	RWTLASR/2526/00385	Date of Issue : 28/06/2025
Registration no.:	RWTLASR/REG2526/02918	Condition of Sample : Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle: 300 ml / Autoclavable Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : British Sikh School, Village Khojewal, Kapurthala (Tubewell 42 mtr, S/L 135 mtr) Sample Collected By Mr. Asish Arora SDE & Mr. Asish Kumar Rana JE / NA
Village :	Not Mentioned	Habitation : Not Mentioned
Block :	Not Mentioned	District : Jalandhar
Latitude :	Not Mentioned	Longitude : Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially
3. This report is not to be reproduce wholly or in part and can't be used by a evidence in court of law
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmation, ND= Not Detected)
5. * Value not available or test not performed for this parameter
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ± 5%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

..... End of the Test Report

Signature
Principal
BRITISH SIKH SCHOOL
Near Science City, Khojewal (Kpt.)

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT

Name & Address of Customer : SDE Water Supply and Sanitation Sub Division No.1 Kapurthala SDE Water Supply and Sanitation Sub Division No.1 Kapurthala		Customer Reference No	No : 464 Dated : 25/06/2025
		Sample Submitted by	Mr.Laknbir Singh
		Date of Sample Receipt	25/06/2025
		Analysis Starting Date	25/06/2025
		Analysis completion Date	25/06/2025
Discipline : Chemical Testing		Group	Water
ULR No.:		Sample Type :	Water
Test Report No.: RWTLASR/2526/00385		Date of Issue	28/06/2025
Registration no.: RWTLASR/REG2526/02919		Condition of Sample	Sealed
Collection Point: Private Submersible		Quantity/Type of Bottle:	500 ml / Amber Colored Glass Bottle
Scheme/Source: Not Mentioned(Not Mentioned)		Location/Depth :	British Sikh School,Village Khojewal,Kapurthala (Tubewell 42 mtr,S/L 135 mtr)Sample Collected By Mr. Asish Arora SDE & Mr. Asish Kumar Rana IE / NA
Village :	Not Mentioned	Habitat	Not Mentioned
Block:	Not Mentioned	Dist	Jalandhar
Latitude :	Not Mentioned	Longitude	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	BDL(0.010)	0.03	0.2	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
2	Lead	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
3	Selenium	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
6	Arsenic(As)	BDL(0.005)	0.01	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	BDL(0.001)	0.003	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
9	Iron(Fe)	BDL(0.005)	1	No Relaxation	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
10	Copper(Cu)	0.017	0.05	1.5	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
11	Uranium	0.013	30	No Relaxation	µg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
12	Manganese(Mn)	BDL(0.005)	0.1	0.3	mg/l	APHA (24th Ed 2023) Method: 3125 B By ICPMS
13	Zinc(Zn)	BDL(0.01)	5	15	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS

Continue on next page...

Reviewed and Approved By

Asish Kumar
Principal
BRITISH SIKH SCHOOL
Near Science City, Khojewal (Kpt.)

Pardeep

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar


REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

14	Barium	0.022	0.7	No Relaxation	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS
----	--------	-------	-----	---------------	------	--

This Report is issued under the following terms & Condition :


1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab.
Amritsar

----- End of the Test Report -----


Principal
BRITISH SIKH SCHOOL
Near Science City, Khojewal (Kpt.)

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal Doha, water works, Kapurthala
dwtlkpt@gmail.com



TC-14458

TEST REPORT

Name & Address of Customer : S.D.E SUB DIV NO 1 DIV (KAPURTHALA) KAPURTHALA		Customer Reference No. No : 278 Dated : 05/06/2025
		Sample Submitted by MR ASHISH RANA J.E
		Date of Sample Receipt 05/06/2025
		Analysis Starting Date 05/06/2025
		Analysis completion Date 06/06/2025
Discipline : Chemical Testing		Group: Water
ULR No.:	TC144592500000101	Sample Type : Water
Test Report No.:	DWTLKPT/2526/000	Date of Issue : 06/06/2025
Registration no.:	DWTLKPT/REG2526/000046	Condition of Sample : Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle: 500 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : BRITISH SIKH SCHOOL KHOJEWAL / NA
Village :	Not Mentioned	Habitation : Not Mentioned
Block:	Kapurthala	District : Kapurthala
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.29	6.5-8.5	No Relaxation	---	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	3	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	---	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	---	IS 3025 (Part 8 - 2023)
5	TDS	225	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	165.4	100	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	160	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2023) EDTA Method
9	Calcium(Ca)	41.68	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	13.6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	21.0	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms and conditions:

- The results apply to the sample as received.
- The sample will be destroyed after retention period unless otherwise specified specially.
- This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Available, NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
- * Value not available or test not performed for the parameter.
- Temperature condition limit: 25±5°C and relative humidity limit: 65±20%.

Reviewed and Approved By

D. K. Kaur
Principal
BRITISH SIKH SCHOOL
Near Science City, Khojewal (Kpt.)

[Signature]
Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Kapurthala

of the Test Report